

Tungmetallhalter i spillvatten vid Visby Reningsverk. Veckoprov Metall in - Årsvi. Bilaga 1d

År	Provtagdatum	Station	Pb mg/l	Cd mg/l	Cu mg/l	Cr mg/l	Hg mg/l	Ni mg/l	Zn mg/l	Ag mg/l
	2018-01-09	in metall	0,002	0,00015	0,15	0,001 <	0,0001	0,003	0,075	0,0002
	2018-02-06	in metall	0,001	< 0,0001	0,1	0,0005 <	0,0001	0,002	0,053	0,0001
	2018-05-15	in metall	0,003	0,00015	0,2	0,002 <	0,0001	0,004	0,13	0,0002
Sammanfattnin										
	Medel		0,002	0,0001	0,15	0,001	0,0001	0,003	0,09	0,00
	Min		0,001	0,0001	0,10	0,001	0,0001	0,002	0,05	0,00
	Max		0,003	0,0002	0,20	0,002	0,0001	0,004	0,13	0,00