

# Tungmetaller i spillvatten vid Visby Reningsverk.

## Veckoprov Metall ut - Årsvis. Bilaga 2e

År	Provtagdatum	Station	Pb mg/l	Cd mg/l	Cu mg/l	Cr mg/l	Hg mg/l	Ni mg/l	Zn mg/l	Ag mg/l
	2018-01-09	ut metall	< 0,0005	< 0,0001	0,029	0,0005	< 0,0001	0,003	0,018	0,00013
	2018-02-06	ut metall	< 0,0005	< 0,0001	0,054	0,0005	< 0,0001	0,002	0,02	0,000094
	2018-05-15	ut metall	< 0,0005	< 0,0001	0,014	0,0005	< 0,0001	0,004	0,018	0,00014
<b>Sammanfattnin</b>										
<b>Medel</b>			<b>0,0005</b>	<b>0,0001</b>	<b>0,0323</b>	<b>0,0005</b>	<b>0,0001</b>	<b>0,0027</b>	<b>0,0187</b>	<b>0,0001</b>
<b>Min</b>			<b>0,0005</b>	<b>0,0001</b>	<b>0,0140</b>	<b>0,0005</b>	<b>0,0001</b>	<b>0,0016</b>	<b>0,0180</b>	<b>0,0001</b>
<b>Max</b>			<b>0,0005</b>	<b>0,0001</b>	<b>0,0540</b>	<b>0,0005</b>	<b>0,0001</b>	<b>0,0038</b>	<b>0,0200</b>	<b>0,0001</b>